

Certificate

Certificate No.:

01 202 CHN/K-160104

Name and address
of the manufacturer:

**ZHEJIANG COMPRESSED FLUID TECHNOLOGY
CO.,LTD
A10 BUILDING 5, NO.96 MUJIN ROAD,GAOXIN
DISTRICT,NINGBO,ZHEJIANG PROVINCE**

According to the test results, the manufacturer is entitled to affix the permit identification of the manufacturer to the pressure equipment produced within the range of Directive 2014/68/EU Article 4.3:



Tested acc. to Directive 2014/68/EU:

Article 4.3

Test report no.:

CHN/K-160104M4

Description of pressure equipment:

The pipe work system made of
1) Aluminium alloys and sealing rubber
2) Stainless steel and sealing rubber
in accordance with ASME B31.1
DN 20-50mm, for PS up to 15bar (-20°C ~ +80°C) or 16bar(-20°C ~ +45°C)
see annex to certificate

Manufacturing plant:

**ZHEJIANG COMPRESSED FLUID TECHNOLOGY
CO.,LTD
A10 BUILDING 5, NO.96 MUJIN ROAD,GAOXIN
DISTRICT,NINGBO,ZHEJIANG PROVINCE.**

The next monitoring is due by end of **March 2020.**

Shanghai, Apr.30, 2019

TÜV Rheinland (Shanghai) Co., Ltd.

Oliver.Zhu



TÜV Rheinland (Shanghai) Co., Ltd.
Shanghai TÜV Rheinland Building, No.177, Lane 777, West Guangzhong Road,
Zhabei District, Shanghai, P.R. China 200072

Certificate

Module A2

according to Directive 2014/68/EU

Certificate No.:

01 202 CHN/Ü-160001

Name and address of the manufacturer:



ZHEJIANG COMPRESSED FLUID TECHNOLOGY CO.,LTD
A10 BUILDING 5, NO.96 MUJIN ROAD,GAOXIN DISTRICT,NINGBO,ZHEJIANG PROVINCE.

According to the test results, the manufacturer is entitled to mark the pressure equipment produced within the range of this module with the mark:

CE 0035

Tested according to Directive 2014/68/EU:

Module A2 – Internal production control plus supervised pressure equipment checks at random intervals

Test report no.:

CHN/Ü-160001M7

Description of pressure equipment:

The pipe work system made of
1) Aluminium alloys and sealing rubber
2) Stainless steel and sealing rubber
in accordance with ASME B31.1 as following:

DN 63-100mm, for PS up to 15bar (-20°C ~ +80°C) or 16bar (-20°C ~ +45°C);
DN 150mm, for PS up to 15bar (-20°C ~ +80°C) or 16bar (-20°C ~ +45°C);
DN 200mm, for PS up to 13bar (-20°C ~ +80°C);

in category I, details see annex to certificate

Manufacturing plant/Supplier:

ZHEJIANG COMPRESSED FLUID TECHNOLOGY CO.,LTD
A10 BUILDING 5, NO.96 MUJIN ROAD,GAOXIN DISTRICT,NINGBO,ZHEJIANG PROVINCE.

During the periodical monitoring, compliance with the directive has been demonstrated. The next monitoring will be performed in **September/2019**.

Shanghai, April. 30, 2019

Location, Date

i.A. Oliver. Zhu



TÜV Rheinland Industrie Service GmbH
Notified Body for Pressure Equipment, ID-No. 0035
Am Grauen Stein, D-51105 Köln, GERMANY

TÜV Rheinland (Shanghai) Co., Ltd.
Shanghai TÜV Rheinland Building, No. 177, Lane 777, West Guangzhong Road, Zhabei District, Shanghai, P.R. China 200072
Tel.: +86-21/ 6108-1425, Fax: +86-21/ 6108-1199, e-mail: oliver.zhu@tuv.com D-014-E-Rev21